

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
			J	1	2
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 08-Dec-2022	4. REQUISITION/PURCHASE REQ. NO. W25G1Q222000QU		5. PROJECT NO.(If applicable)	
6. ISSUED BY LETTERKENNY ARMY DEPOT LETTERKENNY CONTRACTING OFFICE - ACC-RSA-LEAD 1 OVERCASH AVENUE, ATTN: CCAM-MLK, BLDG 2S CHAMBERSBURG PA 17201-4150	CODE W911N2	7. ADMINISTERED BY (If other than item 6)		CODE	
		See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. W911N223Q0007	
			X	9B. DATED (SEE ITEM 11) 29-Nov-2022	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACT ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to answer questions on the solicitation from prospective offerors.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 08-Dec-2022	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

QUESTIONS & ANSWERS

- Q1) What is "app." short for?
A1) "app." Is short for approximately.
- Q2) How many Hoists?
A2) Two each, one-ton hoists.
- Q3) What is the total capacity of the Monorail?
A3) Each 20' span will be required to support one ton (2,000 lbs).
- Q4) Are there any available drawings?
A4) There are no available drawings.
- Q5) What does "...support each of the one-ton air hoists on each app. 20' span" mean?
A5) The configuration is 2 ea. 20' spans (a single 42' beam with a center support creating 2 approximately 20' spans). Each 20' span will support one each one-ton hoist.
- Q6) How many trolley stops are needed? e.g. ...A pair of stops for each hoist or just a pair for the ends of the monorail?
A6) Four each trolley stops are needed - two for each hoist/trolley.
- Q7) What is the "associated equipment" that we have to install with the new airlines?
A7) Airline hangers/festooning.
- Q8) Is there a layout drawing of the current system?
A8) No.

(End of Summary of Changes)