

Project No.: OR DOT 18(2)
 Project: OR58: Fix it Corridor Culverts

Check General or Technical

#	General	Technical	Question	Answer	Date
1		X	I am bidding on the guardrail portion of this project. Bid Item A1000 is for Buried in Backslope Terminal by the each, but they have a minimum of 125 Lnft per the standard drawing. Sheet # D.13 has a length of 85 Lnft and sheet # D.14 has a length of 77 Lnft. Please advise.	The limits/lengths listed on sheets D.13 and D.14 are those of existing guardrail installations. New guardrail needs to meet minimum lengths per the standard drawings	11/15/22
2		X	Is there a Pre Bid Conference for the OR58: Fix-It Corridor Culverts Project?	At this time, we are not planning on having a pre-bid conference. If you have any questions about the Invitation for Bid (IFB), plans, or specs, please email wfl.plans-spec@dot.gov, and we will publicly post responses to your questions on SAM.gov.	11/16/22
3		X	See Plan Sheet Number F.9 More than half of the MP locations referenced in the discharge spreadsheets do not correspond to MP locations provided elsewhere in the plans.	this will be addressed under Amendment A001	11/21/22
4	X		Will the bid date be extended?	this will be addressed under Amendment A001	11/21/22