

Project No.WY FLAP TET TR200(1),  
Project: Sagebrush Connector Pathway

Check General or Technical

#	General	Technical	Question	Answer	Date
1		X	There are not any restoration or seeding items listed with this contract. Are they missing?	Restoration is limited to Placing Conserved Topsoil. The NPS will be reseeding the disturbed areas.	4/6/23
2		X	The table of contents in the aforementioned solicitation shows a Superintendent's Compendium in section J which doesn't seem to be in the solicitation offered. Can you look into adding that section?	will be addressed under Amendment A001	4/6/23
3		X	Section 201.04 (e) states to "Install temporary construction fence to protect vegetation and critical root zones designated to remain as directed by the CO". Is this temporary construction fence paid under Line Item No. A0960 63503-1000 Temporary Traffic Control, Plastic Fence?	No. temporary construction fence to protect vegetation and critical root zones is incidental to 20101-0000 CLEARING AND GRUBBING.	4/17/23
4		X	Section 251.04 States to provide a 12" topsoil layer according to section 624.04. Is it the government's intent to use existing topsoil conserved on the project or to have the contractor purchase and import topsoil for this item?	will be addressed under Amendment A002	4/17/23
5		X	Section 403 specs using 58-34 oil. Would the government please consider using the state grade oils for this area in place of 58-34 which is not common in Wyoming.	Please Bid as shown	4/17/23

6	X		Can you confirm the Solicitation Number please? We are seeing 3 different ones from the invitation to bid, the solicitation form, and the bid bond invitation number.	This will be addressed under Amendment A003.	4/19/23
7					