

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT	1. CONTRACT ID CODE	PAGE OF PAGES
		1 2

2. AMENDMENT/MODIFICATION NO. 040ADV-22-R-0028-0010	3. EFFECTIVE DATE 02/24/2023	4. REQUISITION/PURCHASE REQ. NO. PR-22-GPO-2135	5. PROJECT NO. (If applicable)
--	---------------------------------	--	--------------------------------

6. ISSUED BY GPO 732 North Capitol St NW Washington, DC, 20401, US	7. ADMINISTERED BY (If other than Item 6) Same As Issuing Office
---	---

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NO. 040ADV-22-R-0028
	<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 10/4/2022
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or
 (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of Amendment 040ADV-22-R-0028-0010 is the following:
 1) To provide clarifications to questions 21 and 139 from amendments 007 and 009.
 2) All other factors, terms and conditions will remain the same.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

Responses to Question under Solicitation:

040ADV-22-R-0028

Number	Question	Response	Final Response
21	<p>Q: The SD drawings mention to remove portions of the concrete roof deck slab. The drawings do not mention removing/patching any roofing material. Can you provide info on the existing roofing material, and if there is an existing warranty?</p> <p>Q: Please clarify if there is an existing roof warranty and who holds it.</p> <p>Q: Reference Project Summary Section on Drawing A001. The Roof System is described as a Low Slope Rubber Roof. Please provide a detail or specification for the existing roof system so we know what to price.</p>		<p>Roof was installed in 2015. The warranty is 20 years. The roofing contractor (prime) was: Roofing Resources 600 Chadds Ford Drive, Suite 200 Chadds Ford PA, 19317 PH 610-558-4000.</p> <p>The subcontractor that installed the roof was: Jottan Inc. Commercial roofing contractors One Underwood Court Delran NJ. PH 609-447-6200.</p> <p>Jottan Holds the warranty. The roof material is 2 layers of ISO 95+ insulation 5.7" total thickness. Base and intermediate ply's are Firestone SBS poly. Cap sheet is firestone SBS FR. Contractor is to maintain GPO warranty for all patching and repair work on roof.</p>
139	<p>RFI #73, I previously asked who the contractor is that is allowed to perform the warranted work for the lightning protection system. The answer simply stated "to contact the vendor", however the GPO did not give the name of the vendor or any other company that can be contacted. Can you please help by giving the company name. There are no specifications or names, related to lightning protection, listed in the RFP documents. If you cannot provide a name for the GC to contact, we can only provide an allowance for the work.</p>		<p>B&B Lightning Protection LLC, 47 Virginia Ave, Trenton NJ. 08611 Ph 609-392-1929.</p>