

**Questions and Answers during Advertisement for  
KS FLAP KIN50(1) Cheney Reservoir Access**

**December 22, 2022**

<b>Questions</b>		<b>Answers</b>
<b>1</b>	Is this project tax exempt?	Refer to clause 52.229-3 Federal, State, and Local Taxes on sheet C-12 of the IFB.
<b>2</b>	Will use of temporary traffic signals be allowed rather than use of flaggers?	Submit a traffic control plan in accordance with Section 104, 156, and 635 of the FP and SCR's, MUTCD, and Sheet T9 of the plans for approval by the CO in coordination with the project partners. Note 4 on Sheet T9 states "CO to close only portion of roadway where work will be performed. Construction zone may move each day."
<b>3</b>	Our paving contractor is requesting using a previously approved KDOT asphalt mix design used in Kingman County, KS on K-42 Hwy. Would this be acceptable?	Per FP-14 403.02(a), A KDOT mix approved for use in the last 12 months may be used. Table 403-1 can be disregarded if it conflicts with state DOT standards.