

Bldg 1044 Electrical and Heating Upgrade Photo

REV 01 10/12/22

B1044

Existing feeds to building to be run from new panel in exterior rigid conduit minimum 10' overhead not to interfere with stairs.



New exterior rated 200 amp panel to be located on existing retaining wall on the side facing the conex box North Side of building under the stairs

Bldg 1044 Electrical and Heating Upgrade Photo



Existing Compressor in SE corner of tent area: location for new 208V 30 amp circuit termination.

Distribution Statement A. Approved for public release: Distribution unlimited.