

Date: June 15, 2021

Tech: [REDACTED]

Safe-Tech Inc.

Phone: [REDACTED]

Fire Suppression Inspection Report

Customer	James J. Peters VA Medical Center			Address	130 W. Kingsbridge		City, State, Zip	Bronx, NY 10468		
Contact	[REDACTED]			Phone	[REDACTED]		Protected Area	Ground Floor IT Computer Room		
System Location	Closet by IT Computer Rm			Manufacturer	Reliable		Control Panel	Potter PFC-4410		
Agent	FM-200	HALON	CO2	Inergen	Dry Chem	Water	Battery Backup	2 x 12v 7 AH	Load Test	Left 66 Mhos; Rt 70 Mhos
System Type	24V	12V	110V	Pneumatic	Cable	Battery				
Notifications	Central Station		Building FACP		Start	10:00 AM	Restore	11:30 AM	Operator ID	NA
Shutdowns	NA						VIA		VIA	
Comments:										

Pre-Action Sprinkler Mechanical Information

Size	2 1/2"	Supply PSI	105	Seat PSI	120			Solenoid	OK	Comments:	
Zone		Air PSI	60 OSI	Model B Air Comp				LoAir	OK	System Loc.	Closet by IT Computer Room
Size	Reliable Model B		AC On PSI	40 OSI	AC Off PSI	60 OSI	LoAir	8 OSI		Comments:	

Detection Information

Zone	3	Type	SS i3-2B	Photo-Electric Smoke	Sensativity	2.40%	Activated	Yes	Comments:	Storage/Pre-Action/CO2 Closet	
Zone	3	Type	SS i3-2B	Photo-Electric Smoke	Sensativity	2.20%	Activated	Yes	Comments:	Control Room	
Zone	3	Type	SS i3-2B	Photo-Electric Smoke	Sensativity	2.40%	Activated	Yes	Comments:	Data Center	
Zone	3	Type	SS i3-2B	Photo-Electric Smoke	Sensativity	2.40%	Activated	Yes	Comments:	Data Center	
Zone	3	Type	SS i3-2B	Photo-Electric Smoke	Sensativity	2.40%	Activated	Yes	Comments:	Data Center	
Zone	2	Type	MPS	Serial No	NA	Sensativity	NA	Activated	Yes	Comments:	2 Installed
Zone	2	Type	CO2 Press	Serial No	NA	Sensativity	NA	Activated	Yes	Comments:	Trips system on CO2 discharge
Zone	4	Type	Lo Air	Serial No	NA	Sensativity	10 OSI	Activated	Yes	Comments:	DRIVES LOCAL 6" BELL
Zone	Supv 2	Type	Tamper	Serial No	NA	Sensativity	2 turns	Activated	Yes	Comments:	DRIVES LOCAL 6" BELL
Zone	1	Type	Pressure	Serial No	NA	Sensativity	NA	Activated	Yes	Comments:	DRIVES LOCAL 10" BELL/Strobe
NAC	Alarm	1	10" Bell	Active on Smoke, Manual or Waterflow					Comments:	OK	
NAC	Trouble	2	Chime						Comments:	OK	
NAC	Supervisory	3	6" Bell	Active on Tamper or Low Air					Comments:	OK	
NAC	Charge	4	Solenoid	Active on Heat or Manual					Comments:	OK	
									Comments:	Alarm + Trouble to Class "E" Panel	
									Comments:		

Comments: CO2 pressure switch is wired to activate the Pre-Action system. After the inspection, the system was left in a normal operable condition.
Replace batteries ASAP.

Signing Below will constitute acceptance of the Inspection & Fire Services Noted:

Customer Signature _____

Printed Name _____

Date _____

6/15/2021

Date: June 15, 2021

Tech: [REDACTED]

Safe-Tech Inc.

Phone: [REDACTED]

Fire Suppression Inspection Report

Customer	James J. Peters VA Medical Center			Address	130 W. Kingsbridge		City, State, Zip	Bronx, NY 10468		
Contact	[REDACTED]			Phone	[REDACTED]		Protected Area	Ground Floor MRI Suite		
System Location	Closet by MRI Computer Rm			Manufacturer	GEM		Control Panel	Potter PFC 100RC		
Agent	FM-200	HALON	CO2	Inergen	Dry Chem	Water	Battery Backup	2 x 12v 7 AH	Load Test	Left 162 Mhos; Rt 118 Mhos
System Type	24V	12V	110V	Pneumatic	Cable	Battery				
Notifications	Central Station		Building FACP		Start	1:00 PM	Restore	2:00 PM	Operator ID	NA
Shutdowns	NA						VIA		VIA	
Comments:	SAFETY 718.584.9000 * 3644 or 3436 or Rick *6605									

Pre-Action Sprinkler Mechanical Information

Size	4"	Supply PSI	110	Seat PSI	115			Solenoid	OK	Comments:	GEM VALVE
Zone		Air PSI	5	Reliable Model B-S1	NA			LoAir	3 PSI	System Loc.	Closet by MRI Computer Room
Size	Reliable Model B			AC On PSI	4	AC Off PSI	5			Comments:	

Detection Information

Zone	1	Type	Fenwal	Serial No	135* FT Heat	Sensativity	NA	GA	NA	Comments:	There are 25 devices +/-
Zone	2	Type	MPS	Serial No	NA	Sensativity	NA	GA	NA	Comments:	Inspected/actuated OK
Zone	3	Type	Lo Air	Serial No	NA	Sensativity		GA	NA	Comments:	OK at 3 PSI
Zone		Type	Tamper	Serial No	NA	Sensativity	2 Turns	GA	NA	Comments:	Direct to Class "E" panel - SET PROPERLY
Zone	Alarm	Type	Pressure	Serial No	NA	Sensativity	NA	GA	NA	Comments:	Direct to Class "E" panel
NAC	Alarm	1	Bell	ANY						Comments:	
		2	Solenoid							Comments:	OK
										Comments:	Alarm + Trouble to Class "E" Panel
										Comments:	
										Comments:	

Comments: NO DEFECTS FOUND.

Signing Below will constitute acceptance of the Inspection & Fire Services Noted:

Customer Signature _____

Printed Name _____

Date _____

6/15/2021