

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1   2</div>	
2. AMENDMENT/MODIFICATION NO. <b>0002</b>		3. EFFECTIVE DATE <b>14-Sep-2023</b>		4. REQUISITION/PURCHASE REQ. NO. W81G6730532764		5. PROJECT NO.(If applicable)	
6. ISSUED BY <div style="font-size: small;">CONTRACTING DIVISION USACE, ST PAUL 332 MINNESOTA STREET SUITE E1500 ST PAUL MN 55101-1323</div>		CODE <b>W912ES</b>		7. ADMINISTERED BY (If other than item 6) <div style="text-align: center; font-size: large;"><b>See Item 6</b></div>			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. W912ES23Q0084	
				X		9B. DATED (SEE ITEM 11) 28-Aug-2023	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  The purpose of this amendment is to add to the Q&A section.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  14-Sep-2023	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

SECTION 00 10 00 - SOLICITATION

The following have been modified:

QUESTIONS AND ANSWERS

Q1: Will engineered drawings be provided indicating conduit/conductor sizing and types?

A1: No. Existing electrical diagrams have been provided, see Attachment 4.

Q2: Is the new pad at the same elevation as the existing generator building?

A2: Yes

Q3: We are assuming that there is no automatic transfer switch, is this a "Kirk Key" installation?

A3: Yes, the circuits that are on utility will have their sources transferred with kirk key.

Q4: Will concrete sawing be required?

A4: Yes

Q5: Has the Government considered installing the new generator within the building ? Easier maintenance, much cheaper than a housed unit, reuse existing storage tank etc.

A5: Consideration was made, but the Government wants to remove the noise and potential exhaust pollution from having the unit inside of the building.

Q6: Is there a requirement for a new service entrance rated ATS? NEMA 1 or 3 R?

A6: If using an ATS, it is not required to be service entrance rated. Enclosure should be NEMA 3R.

(End of Summary of Changes)