

Questions and Answer #2
MILPERS FLOORING REPLACEMENT BUILDING 8517

Q: What is the period of performance?

A: The period of performance begins at the date of award and should be concluded within 90 days.

Q: Is there an official SF 1442 for this project?

A: No, there is not. The Combined Solicitation/Synopsis is the official document used in lieu of the SF1442.

Q: Do you have the ounce weight for the carpet tile?

A: Any standard ounce weight for commercial use is appropriate.

Q: Page 3 of SOW Measurements for work: labels Back Office #1- 19' x 19' and Back Office #2- 18' x 24', but on page 2 of SOW 1.11. The dimensions of the room requiring work are as follows: labels Back Office 1 and Back Office 2 both as being 432 Sq feet. Which are the accurate measurements, Page 3 of SOW Measurements for work, or page 2 of SOW 1.11?

A: Measurements are 19'x19' Back Office #1 and 18'x24' Back Office #2

Q: Please elaborate on type, size, and amount of transitional strips?

A: What we currently have down looks like vinyl about 1"3/4 to 2" and brown in color. Brown or black 1"3/4 to 2" vinyl transitional strips are what we are looking for.

Q: Are you able to send pictures of the current light brown ceramic/stone tile and light blue carpet tile, in order to get the closest match of the new material?

A: Pictures are below. The ceramic tile pictured is the light brown to be matched and the carpet is the light blue to be matched.

