

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 10
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 23-Mar-2023	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY M67001MARINE CORPS FIELD CONTRACTING SYS BOBBI WEBSTER PSC BOX 8018 CHERRY POINT NC 28533	CODE M67001	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. M6700123Q1047	
		X	9B. DATED (SEE ITEM 11) 22-Feb-2023	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACT ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to further define the Performance Work Statement and extend the quotes due by date to 03 April 2023 at 11:00 AM (EDT). See Summary of Changes for further details.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		23-Mar-2023

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The following items are applicable to this modification:

SUMMARY OF CHANGES

SECTION SF 1449 - CONTINUATION SHEET

The following have been modified:

GENERAL INTENTION. The intent of this action is to establish a requirements contract to provide fire extinguisher maintenance services for Marine Corps Air Station Cherry Point, to include the Fire Department, Environmental Affairs Department, Fleet Readiness Center East located aboard Marine Corps Air Station Cherry Point, NC. Additionally, services will be provided to four local off site Marine Corps Units to include Bombing Target 11 (BT-11), Marine Corps Landing Field (MCALF) Bogue, MCALF Atlantic, and Marine Corps Outlying Field Oak Grove. All fire extinguisher maintenance services shall be provided in accordance with the Performance Work Statement.

TYPE OF CONTRACT. This contract will be a firm-fixed price requirements type contract. The quantities listed in the schedule are an estimate only and do not represent that the estimated quantities will be required or ordered. Funds shall be obligated by issuance of Task Ordered for precise quantities (FAR 52.216-21, Requirements OCT 1995).

PERFORMANCE PERIOD. The contractor shall provide the specified services for a period of three years upon award of this requirements contract.

SOLICITATION/CONTRACT FORM

The required response date/time has changed from 08-Mar-2023 11:00 AM to 03-Apr-2023 11:00 AM.

SUPPLIES OR SERVICES AND PRICES

CLIN 0001

The CLIN extended description has changed from:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.1

To:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.1
Not to Exceed 300 extinguishers per Task (Unit of Issue)

CLIN 0002

The CLIN extended description has changed from:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.2

To:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.2
Not to Exceed 150 extinguishers per Task (Unit of Issue)

CLIN 0003

The CLIN extended description has changed from:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.3

To:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.3
Not to Exceed 15 extinguishers per Task (Unit of Issue)

CLIN 0004

The CLIN extended description has changed from:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.4

To:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.4
Not to Exceed 80 extinguishers per Task (Unit of Issue)

CLIN 0005

The CLIN extended description has changed from:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.5

To:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.5
Not to Exceed 25 extinguishers per Task (Unit of Issue)

CLIN 0006

The CLIN extended description has changed from:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.6

To:

For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.6
Not to Exceed 25 extinguishers per Task (Unit of Issue)

The following have been added by reference:

52.232-37

Multiple Payment Arrangements

MAY 1999

The following have been added by full text:

PERFORMANCE WORK STATEMENT

1.0 Scope. The purpose of this requirement is to establish a requirements contract for fire extinguisher maintenance services of portable hand-held fire extinguishers aboard Marine Corps Air Station Cherry Point, North Carolina, to include the Air Station Fire Department, Environmental Affairs Department, and Fleet Readiness Center East located aboard Marine Corps Air Station Cherry Point, NC. Additionally, services will be provided to four local off site Marine Corps Units to include Bombing Target 11 (BT-11), Marine Corps Auxiliary Landing Field (MCALF) Bogue, MCALF Atlantic, and Marine Corps Outlying Field Oak Grove. The contractor shall provide all parts, tools, equipment, supplies, labor, and transportation necessary for the inspection, maintenance, recharging, testing, and disposal of fire extinguishers in accordance with this Performance Work Statement (PWS).

1.1. The contractor shall perform all services in accordance with the provisions of National Fire Protection Association (NFPA) Standard 10, and all applicable federal, state, and local laws and regulations. Services shall include but not be limited to the following services: inspection, maintenance, recharging, testing, and disposal of all portable hand-held fire extinguishers located aboard Marine Corps Air Station Cherry Point, NC. All services shall be performed by a licensed technician certified in accordance with federal, state, and local laws and regulations relating to fire extinguisher maintenance. Fire extinguishers located on government vehicles may be included however fire extinguishers located on fixed-wing and rotary-type aircraft are not included in this requirement.

2.0 Applicable Documents.

- 2.1. National Fire Protection Association 10, Standard for Portable Fire Extinguishers (current edition)
- 2.2. Code of Federal Regulations, 29 CFR 1910.157, Portable Fire Extinguishers
- 2.3. United Facilities Criteria 3-600-01, Fire Protection Engineering for Facilities, May 2021
- 2.4. FRCEASTINS 5000.1B
- 2.5. Air Station Order 1020.3D

3.0 Requirements. New (to include back-up and permanent replacement) fire extinguishers are not covered under this contract as they are considered centrally managed items that must be obtained through the government mandatory sources of supply (GCSS/FEDMALL/DLA/GSA/etc.). All repair parts to complete the required fire extinguisher maintenance services shall be new and unused and be provided at no extra costs by the contractor. Fire extinguishers to be serviced under this Purchase Order shall remain the property of the Government and vary in size, type, quantities, and locations aboard the base. The estimated fire extinguisher type quantities and estimated building location quantities aboard the base are listed as follows:

Type	Estimated Quantity	Estimated Buildings
ABC Fire Extinguishers – 5 lbs.	260	90
ABC Fire Extinguishers – 10 lbs.	4160	240
ABC Fire Extinguishers – 20 lbs.	660	60
C02 Fire Extinguishers – 5 lbs.	86	10
C02 Fire Extinguishers – 10 lbs.	180	75
C02 Fire Extinguishers – 15 lbs.	110	50
C02 Fire Extinguishers – 20 lbs.	210	200
C02 Fire Extinguishers – 30 lbs.	110	50
Halotron Fire Extinguishers – 65 lbs.	30	5
Class D Fire Extinguishers – 30 lbs.	60	35
Class K Fire Extinguishers – 10 lbs.	35	15
Clean Agent Fire Extinguishers – 13.5 lbs.	30	20
Water Fire Extinguishers – 2.5 gallons	70	25
Dry Chemical Fire Extinguishers – 2.5 lbs.	50	5
Dry Chemical Fire Extinguishers – 5 lbs.	50	5
Dry Chemical Fire Extinguishers – 10 lbs.	150	10
Dry Chemical Fire Extinguishers – 20 lbs.	150	10

The below table reflects the maximum number of extinguishers to be serviced per Task (Unit of Issue):

CLIN 0001 Annual Maintenance	CLIN 0002 6yr Maintenance	CLIN 0003 Recharge Services	CLIN 0004 Hydrostatic Testing	CLIN 0005 Corrective Maintenance	CLIN 0006 Remove/ Disposal
300	155	15	80	25	25

Sample Task Order

<u>Item No.</u>	<u>Supplies/ Services</u>	<u>Quantity</u>	<u>Unit of Issue</u>	<u>Unit Price</u>	<u>Total Price</u>
0001	Annual Maintenance FFP For various types of Fire Extinguishers in accordance with Performance Work Statement sections 3.0 and 3.1 Not to exceed 300 extinguishers per unit of issue Actual # of extinguishers to be serviced for this task order: 520 (See attached list for details) Period of Performance: 3 months ADC	2	Task	\$	\$

3.1. Annual Maintenance. All fire extinguishers shall be inspected annually and subjected to applicable annual maintenance procedures in accordance with NFPA 10 (current edition) for the type of fire extinguisher being serviced (i.e., C02, Class D, Class K, etc.). For annual maintenance, the year shall start on the first day the maintenance is performed and end one calendar year later. At each annual maintenance, fire extinguishers shall be placed in a fully charged and operable condition free from defects which may cause malfunctions. Cartridges of every cartridge-operated extinguisher shall be accurately weighed annually in accordance with the manufacturer's recommendations. Upon completion of the annual maintenance service, a safety pin compatible with the valve required by the ANSI/UL standards shall be installed and held in place with a tamper seal. When performing the required maintenance, the contractor shall ensure, for each extinguisher, in accordance with NFPA 10, that:

- a) The extinguishers are mounted in the designated location and there are no obstructions of access or visibility of the extinguisher
- b) Operating instructions on the nameplate are legible and facing outward
- c) Safety seals and tamper indicators are not broken or missing
- d) The extinguisher is at its proper gross weight as specified on the nameplate
- e) Fullness determined by weight or hefting for self-expelling-type extinguishers, cartridge-operated extinguishers, and pump tanks is verified
- f) If applicable, the condition of tires, wheels, carriage, hose, and nozzle for wheeled extinguishers are verified
- g) There is no obvious physical damage, corrosion, leakage, or clogging
- h) The pressure gauge reading, or indicator is in the operable range or position
- i) If applicable, verify operability on non-rechargeable extinguishers using push-to-test pressure indicators
- j) Required labeling is in place
- k) All extinguishers are properly tagged in accordance with NFPA 10; and,
- l) Ensure the extinguisher is DOT and OSHA compliant

Further, all serviced fire extinguishers shall be fitted with an annual maintenance tag for inspection purposes. The annual maintenance tag shall be attached to each portable fire extinguisher in such a position to be conveniently inspected. The annual maintenance tag may be attached to the fire extinguisher by means of wire, string, plastic ties, or a self-adhesive tag approved by the Fire Department AHJ. The annual maintenance tag shall contain the required information:

- a) "Do Not Remove by Order of the Fire Department AHJ"
- b) Concern name as listed on license
- c) Concern business location
- d) License number ("E" Number) and License Type
- e) Service Maintenance / New Extinguisher Block
- f) Date service performed
- g) Certificate of Registration. Provide printed "EE" Number followed by space for number
- h) The Seal of Registration of the Office of the Fire Department AHJ
- i) Space or line for signature of person performing or supervising the service work
- j) Valid local telephone number for the licensed concern

3.1.1. The contractor will notify the Technical Point of Contact of any fire extinguishers found to be unserviceable or unusable to ensure they are properly disposed of, and a fire extinguisher of adequate type and size is restored in its place.

3.2. Six-Year Maintenance of Fire Extinguishers. Every six years, whether the fire extinguisher is used or not, all stored-pressure type extinguishers that require a twelve-year hydrostatic test shall undergo six-year maintenance. Extinguishers shall be emptied, inspected internally and externally, and recharged. Upon completion, a six-year maintenance label shall be affixed to the side or rear of the extinguisher cylinder, indicating the month and year service was performed.

3.3. Recharging of Fire Extinguishers. If recharging is required, the contractor shall ensure that: the extinguisher is emptied of all its contents; essential mechanical parts are dismantled, inspected, and cleaned; any defective or worn parts are replaced; cylinder is filled with proper amount of extinguishing agent; and fire extinguisher is reassembled and pressurized with verification of service collar in place. A leak test shall be performed in order to ensure proper containment of pressure and contents.

3.4. Hydrostatic Testing of Fire Extinguishers. Stored-pressure fire extinguishers shall be hydrostatically tested according to intervals and procedures specified by NFPA 10 and DOT.

3.5. Corrective Maintenance Services. This shall include but not be limited to misplacement, exchange, fire extinguishers that have had a scheduled maintenance performed or will have a scheduled maintenance performed but due to resulting damage and/or weather effects or operational reasons may require evaluation, servicing, and/or repair. The vendor will restore a fire extinguisher to full operating capability. All work shall be in accordance with NFPA 10/OSHA/DOT requirements. All parts utilized must meet original equipment manufacturer's specifications. The replacement of safety disc assembly, pressure gauges, valve stems, and replacement of wheels and or hose/nozzle assemblies will be determined at time of inspection and will be coordinated with the Technical Point of Contact listed in each Task Order and/or in Section 9.0 of this Performance Work Statement.

3.6. Removal and/or Disposal of Fire Extinguishers. When an extinguisher is removed from service, the contractor will notify the Technical Point of Contact listed in each Task Order and/or Section 9.0 of this Performance Work Statement prior to condemning, disposing of, and recycling a fire extinguisher and its contents in accordance with federal, state, and local laws and environmental regulations. Replaced parts shall be disposed of by the contractor in accordance with federal, state, local laws, and environmental regulations (if applicable).

3.6.1. Fire extinguishers removed from service for maintenance or recharge shall be temporarily replaced by a fire extinguisher suitable for the type of hazard being protected and shall be of at least equal rating.

Fire extinguishers may not be removed for on-site service without providing a temporary replacement. On-site means services provided in a vehicle approved for servicing of fire extinguishers and located on the immediate building property where work is performed.

3.6.2. The contractor shall immediately notify the Technical Point of Contact listed on the Task Order and/or Section 9.0 of this Performance Work Statement if an extinguisher is missing, not in its designated location, appears to have been discharged for no apparent reason, or is being disposed of due to test failure or being rendered inoperable.

3.6.3. The Government may on an as needed basis submit a Task Order for disposal of fire extinguishers.

4.0 Contractor Provided Tools and Equipment. The contractor shall provide all necessary tools and equipment required for the successful and safe performance of all requirements of this Performance Work Statement, as required by OSHA. The contractor shall have the capabilities to service ABC multi-purpose dry chemical, Halotron, BC stored chemical, purple K dry chemical, carbon dioxide, class K wet chemical, class D dry chemical, and stored water pressure fire extinguishers.

4.1.1. The contractor shall, without additional expense to the Government, obtain all appointments, licenses, and permits required for the performance of the services required under this purchase order. The contractor shall comply with all applicable federal, state, and local laws. Evidence of such permits and licenses shall be provided to the government upon request.

4.1.2. The contractor shall provide the name or names, to the government Technical Point of Contact listed in Section 9.0, of the responsible supervisory person or persons authorized to act for the contractor and subcontractors including addresses and telephone numbers for use in the event of an emergency. Written notification to the government Technical Point of Contact listed in Section 9.0 shall be provided as changes occur and additional information becomes available.

4.1.3. All contractor employees assigned to work aboard must be eligible to gain base access and shall obtain the required employee and vehicle passes. The contractor shall, prior to the start of a Task Order, submit to the Technical Point of Contact listed in Section 9.0, the number of personnel and names of personnel expected to be utilized to complete the Task Order. The Government will issue badges without charge and the contractor employee is required to wear the badge over the front of their outer clothing so that it is visible at all times while completing the performance of the Task Order aboard Marine Corps Air Station Cherry Point and the Fleet Readiness Center East. When an employee leaves the Contractor's service, the employee's pass and badge shall be returned to the Government within 5 calendar days of departure.

5.0 Quality Assurance. The Fleet Readiness Center East's Mission and Workforce Safety Division, Environmental Affairs Department, the Marine Corps Air Station Cherry Point Fire Prevention Department, and the units designated point of contact listed within each Task Order will be responsible to monitor and inspect the contractor's performance in order to ensure performance in accordance with the requirements of this Performance Work Statement and all federal, state, and local laws. Contractor performance will be evaluated through intermittent on-site inspections and receipt of comments from customers.

5.1.1. The contractor will furnish sufficient personnel to perform all work specified within this Purchase Order and subsequent Task Orders. The contractor shall not employ any person whose employment under this award could in any way result in a conflict of interest with the mission of Marine Corps Air Station Cherry Point or the Fleet Readiness Center East. All personnel employed by the contractor in the performance of this purchase order, or any agent of the contractor entering the Government installation shall obey all regulations of Marine Corps Air Station Cherry Point and Fleet Readiness Center East.

5.1.2. The contractor shall be solely responsible to train/certify their personnel necessary to execute this purchase order and subsequent task orders. The contractor is responsible for obtaining certification and

ensuring that all certificates are maintained for the duration of this contract. If certification requirements change, the contractor shall be required to update certification within 90 days of the change. Inspections will be conducted as needed.

5.1.3. The contractor shall be responsible for employee competency, conduct, and disciplinary actions with respect to their employees. The contractor's employees shall conduct themselves in a proper, efficient, courteous, and businesslike manner at all times. The removal from the job site of contractor personnel shall not relieve the contractor of the requirement to provide personnel to perform the specified tasks as outlined in this Performance Work Statement.

5.1.4. The contractor shall comply with all Marine Corps Air Station Cherry Point and Fleet Readiness Center East's security requirements. The Government reserves the right to deny access to any contractor employee to enter Marine Corps Air Station Cherry Point and/or Fleet Readiness Center East if his or her presence would be detrimental to the mission or performance of work in this Performance Work Statement. The Government reserves the right to require removal of any contractor employee from the job site who endangers persons or property or whose continued employment is inconsistent with the mission. In such cases the Government's Technical Point of Contact will advise the contractor of the reason for requesting an employee's removal or withdrawing an authorization to enter the installation.

5.1.5. The contractor shall ensure that all assigned personnel maintain a standard of grooming and personal appearance in accordance with Air Station Order 1020.3D and the Fleet Readiness Center East's standards (if applicable).

5.1.6. The contractor shall ensure that the purchase, use, handling, storage, and disposal of all toxic, hazardous, and special materials and wastes are in accordance with current federal, state, and local environmental protection regulations.

6.0 Inventory List. The Government will provide the contractor an inventory list, that shall include the building number, location, extinguisher type and size, and serial number, date(s) serviced, and the date next service is due at the issuance of each Task Order of the required extinguishers to be serviced for stated Period of Performance aboard Marine Corps Air Station Cherry Point, NC. The contractor shall provide a complete written report to the Technical Point of Contact listed on the Task Order and/or Section 9.0 of this Performance Work Statement of any changes which may include but not be limited to location changes, exchange/new extinguishers, serial number updates, service dates, and updated next service date due.

7.0 Deliverables.

7.1. Contract Administration and Management Points of Contact: The contractor shall provide a contract manager (supervisor) who shall be responsible for the performance of work. The name of the responsible person and an alternate who shall act for the contractor when the manager is absent shall be designated in writing to the Contracting Officer upon award. The contract manager and alternate shall have full authority to act for the contractor on all contract matters relating to daily operation of this contract. The contract manager or alternate shall be available during normal operating hours as described in this Performance Work Statement.

7.2. Service Report: The contractor shall provide a complete written service report of all fire extinguisher maintenance and servicing accomplished upon completion for each Task Order. The report shall be submitted to the Technical Point of Contact listed on the Task Order. The service report shall include the quantity of fire extinguishers serviced, service type, building, location, serial number, a record of conditions found, repairs, recharging, and all replacement parts used. All contractor created records, documents, and associated papers used for the performance of this contract and/or provided by the Government during the period of this contract become Government property and will be returned to the Government upon contract completion or termination and will be available for Government review as needed or as requested.

8.0 Operating Hours. Normal operating hours for the Fleet Readiness Center East are Monday through Friday from 0600-1530. Normal operating hours for Environmental Affairs Department are Monday through Friday from 0600-1500. Normal operating hours for Marine Corps Air Station Cherry Point Fire Prevention department are Monday through Friday from 0700-1600. The contractor is responsible for conducting the fire extinguisher maintenance services between the listed normal operating hours Monday through Friday except on recognized federal holidays or when the base is closed due to local or national emergencies, administrative closings, or similar government directed closings. The contractor is responsible to coordinate schedules with the Technical Point of Contact listed within each Task Order.

8.0.1 Recognized Federal Holidays:

Federal Holiday	Time of Observance
New Year's Day	1st of January
Martin Luther King, Jr. Day	3rd Monday in January
President's Day	3rd Monday in February
Memorial Day	Last Monday in May
Juneteenth	19th of June
Independence Day	4th of July
Labor Day	1st Monday in September
Columbus Day	2nd Monday in October
Veteran's Day	11th of November
Thanksgiving Day	4th Thursday in November
Christmas Day	25th of December

Any holidays falling on a Saturday will be observed on the preceding Friday; holidays falling on a Sunday will be observed on the following day. The base (to include all units aboard MCAS Cherry Point) is closed on recognized Federal Holidays and therefore services are not required and will not be provided on Federal Holidays.

9.0 Technical Points of Contact:

Marine Corps Air Station Cherry Point Fire Prevention Department

Primary: Brandee Ridgway, brandee.ridgway@usmc.mil, 252-466-4008

Alternate: Christopher Boudreau, christopher.j.boudre@usmc.mil, 252-466-4898

Fleet Readiness Center East

Safety Office: 252-464-7015

Primary: Glen Coleman, glenn.a.coleman4.civ@us.navy.mil, 252-464-5413

Alternate: Kari Wilson, kari.s.wilson.civ@us.navy.mil, 252-464-9163

Environmental Affairs Department

Primary: Kurt Avellar, kurt.avellar@usmc.mil, 252-466-3117

(End of Summary of Changes)