

Department of Veterans Affairs

AMENDMENT TO REQUEST FOR LEASE PROPOSAL (RLP)

1. RLP No. 36C24522R0113	2. Amendment No. 0003	3. Effective Date 3/2/2023	4. Page 1	Of 1
-----------------------------	--------------------------	-------------------------------	--------------	---------

5. ISSUED BY

Department of Veterans Affairs
Network Contracting Office 4
Specialized Team
1111 East End Boulevard
Wilkes-Barre PA 18711-0030

6. Description of Amendment

The purpose of this amendment is to provide a written response to a question raised during the Pre-Proposal Meeting held on February 27, 2023 @ 1:00 PM EST.

Question: Will the x-ray room require lead lining and if so, can you elaborate on the specifications needed?

Answer: Lead lining is required, it will be 1/8" thick.

No additional clarification or questions were raised pertaining to the Solicitation or Exhibits.

Except as provided herein, all terms and conditions of the document referenced in Item 1, as heretofore changed, remains unchanged and in full force and effect

7. Name and Title of Signer (Type or Print)

8. Name and Title of Contracting Officer (Type or Print)

Robertta Smiley
Lease Contracting Officer

9. Offerer

10. Date Signed

11. United States of America

12. Date Signed

(Signature of Person Authorized to Sign)

By _____
(Signature of Contracting Officer)