

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.

1. CONTRACT ID CODE

PAGE 1 OF 4 PAGES 4

2. AMENDMENT/MODIFICATION NUMBER
00073. EFFECTIVE DATE
3/9/20224. REQUISITION/PURCHASE REQ. NUMBER
603-23-3-2311-00035. PROJECT NUMBER (if applicable)
603-22-601

6. ISSUED BY CODE

90C

7. ADMINISTERED BY (If other than Item 6)

CODE

90C

Department of Veterans Affairs
 Network Contracting Office 9 (90C)
 NCO 9
 1639 Medical Center Parkway, Suite 400
 Murfreesboro TN 37129

Network Contracting Office 9
 Department of Veterans Affairs
 Network Contracting Office (90C)
 1639 Medical Center Parkway Suite 400
 Murfreesboro TN 37129

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)

To all Offerors/Bidders

(X)

9A. AMENDMENT OF SOLICITATION NUMBER

36C24923R0031

9B. DATED (SEE ITEM 11)
03-09-2023

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED (SEE ITEM 13)

CODE

FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of this amendment is to provide responses to RFI's.

See attached.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

Jeffery A. Ridenour
Contracting Officer

VA-VHA-RPOC-2022-143389

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

(Signature of person authorized to sign)

(Signature of Contracting Officer)

**Project Name: Louisville ASU PACU Safety Improvements
Project No.: 603-22-601**

RFI #	QUESTION	RESPONSE	TO BE ANSWERED BY	Discipline
115	RFI 051 says door operators and handwave hardware information is listed on sheet A-404. Please confirm if new power wire or low voltage wire needed for reinstalling existing operators or will they connect to existing wire in existing circuit.	YES, new wire will be required for the reinstallation of existing door operator and handwave devices.	VA/ACG	
116	RFI 055 states that fire alarm work is included in this project. There does not appear to be any fire alarm work shown on the plans and there is not a spec for it. Please clarify the fire alarm work.	The fire alarm work is contained to providing "Fire Alarm Strobes in the bathrooms within the area of work. A "Strobe" spec will be provided.	VA/ACG	
117	Per RFI 034 all work inside ICRA barriers are during normal hours. Shutdowns and work outside ICRA is after hours. However, RFI 064 says all work is to be performed after hours. Please clarify.	All work is after hours.	VA/ACG	
118	RFI 082 says 3rd floor drawings will be provided to show areas below work areas to determine scope of work required in those 3rd floor areas. However, no drawings have been provided to date. Please provide these 3rd floor drawings.	Drawings provided by the VA are attached.	VA	
119	RFI 083 states that the area below the restrooms is a chemistry lab. Work in these areas typically require special ICRA requirements. What ICRA requirements are to be followed in the chemistry lab below the restrooms? Please provide locations for ICRA in the lab.	Level IV ICRA	VA/ACG	
120	RFI 083 states that the area below the restrooms is a chemistry lab. Work in these areas typically require special work hours. What work hours are to be followed in the chemistry lab below the	Level IV ICRA	VA/ACG	

	restrooms?			
121	RFI 104 states the symbol "F is for fire alarm devices and can be seen on the symbol legend on sheet ET-001. After closer review there does not appear to be a symbol "F" called out on sheet ET-001 denoting fire alarm. Please provide the device type and basis of design for these items."	See the Fire Alarm Symbol Legend in the lower right-hand corner of Sheet ET-001. Strobe spec is pending.	VA/ACG	

Attachment #	Title	Date	# Pages
8	SECTION 28 31 00 FIRE DETECTION AND ALARM	12-14-2022	18
9	Plumbing As-Built Drawings	03-09-2023	2