

REQUEST FOR INFORMATION REPORT (RFI)		RFI NO. 002	PAGE NO. Page 1 of 1
SOLICITATION NO. FA660623R0002	SOLICITATION TITLE YTPM 17-0012, REPAIR HVAC BLDG 1510		
Contractor's Request for Information			
REQUESTED BY:	DATE REQUESTED: 13 FEBRUARY 2023	Potential Cost Impact [No] Potential Schedule	
SUBCONTRACTOR			
RFI			
DRAWINGS			
INFORMATION REQUESTED:			
ATTACHMENTS FROM CONTRACTOR: (1 attachment)			
<p>#1. The SOW calls for installation of wall-mounted ductless split systems for the three server rooms. Server room 1 would get five 3-ton indoor units, Server room 2 and 3 would each get two 3-ton indoor units. The SOW is not clear if these should each be separate one-to-one split systems or supplied as separate VRF systems. If one-to-one split units were used, each indoor unit would have its own condenser and separate refrigeration circuit and controlling thermostat (9 condensers for 9 indoor units). If VRF systems were used, there would be three separate condensers sized to feed their respective indoor units, meaning that server room 1 for example would have an approximate 15-ton condenser with one set of refrigerant piping with branches to connect the five indoor units and operate off of one thermostat in the room. Please confirm the Government intent.</p> <p>WARB Response #1: The intent is to have nine (9) separate condensers connected individually to nine (9) separate indoor units.</p>			
NOTE: THE RFI SYSTEM IS INTENDED TO PROVIDE AN EFFICIENT MECHANISM FOR RESPONDING TO CONTRACTOR'S REQUESTS FOR INFORMATION. IT DOES NOT PROVIDE AUTHORITY TO PROCEED WITH ADDITIONAL WORK. IF THE CONTRACTOR CONSIDERS THE RFI RESPONSE A CHANGED CONDITION, PROVIDE WRITTEN NOTICE TO THE CONTRACTING OFFICER'S REPRESENTATIVE IN ACCORDANCE WITH CONTRACT PROVISIONS.		QA REVIEWER'S SIGNATURE	DATE