

Connecticut Air National Guard

103 AW at Bradley ANGB, East Granby, CT

Solicitation: W50SC2-23-R-0001

Requests for Information (RFIs)

Item	RFI	Response
Thursday, December 1, 2022		
1	Solicitation references Exhibit C at p.21, para 2.5.3.2. Can we submit completed CPARS evaluation in lieu of Exhibit C?	No, the Government will pull and review CPARS evaluations seperately from what is submitted as part of the proposal package.
2	Section 00100 of the solicitation, para 14 on page 18 references Brand Name Justification and Approval (J&A), Control No. 22-39. Where can we find this J&A.	The J&A has been posted to SAM.gov at the same time as this RFI Log.
Thursday, December 22, 2022		
3	019113 states "The Government shall hire an Independent Commissioning Authority..." Do I understand that the GC is not required to carry Commissioning in their cost?	The A-E is the Commissioning Authority and the GC will not incur the cost of the A-E for their commissioning efforts.
4	Please confirm that UFC 3-520-01 and UFGS Section 26 05 19.10.10 shall apply to this project. Specifically, please confirm that bidders are permitted to utilize the type(s) of material(s) described in UFC 3-520-01 and UFGS Section 26 05 19.10.10 applicable to their scope of work despite any potentially contradictory provisions in the design plans and specifications.	The building design complies with UFC requirements, however, UFGS specs are not part of the project. The contractor shall provide materials as specified in specification 260519 FL - Low-Voltage Electrical Power Conductors and Cables in the construction documents. Also, see FAR clause 52.236-5 and DFARS clause 252.236-7001.