

Bldg 1044 Electrical and Heating Upgrade Photo

B1044

Existing feeds to building
to be run from new panel
in exterior ridgid conduit
minimum 10' overhead
not to interfere with stairs.

New exterior rated 200 amp panel to be
located on existing retaining wall on the
side facing the conex box