

Questions	Answers
Is all geotextile innerduct referenced in the SOP existing?	Assuming SOP refers to SOW, 'all' is not existing. Requirement calls for approx. 110' of new.
Are there any limitations or designated areas as to where we can pump the water of the manholes? There will be multiple pumps utilized at the same time during installation.	See 2.2.1.1
Is there a particular type of fire caulk or expansion foam required to fill/seal any cable penetrations?	Just meet Industry Standards for sealing MH/HH ducts. NO EXPANSION FOAM in MH/HH's.
It appears that there may be a one lane shutdown on the road where there are two (2) manholes located. Please advise on the requirements for a partial road shutdown to perform the work. Will an engineered traffic plan or any kind of military escort to block a lane of traffic be required?	Properly 'cone'/tape off that lane. No traffic plan required.
If a gel filled flat drop style cable would be an option to consider should we run into trouble sourcing a standard RUS 12ct OSP cable and if that cable should be OSP dielectric or shielded	NO. please stay with what is in the SOW. SOW has been revised to allow indoor/outdoor cable.