



SYSTEM LEGEND:

HPS = HIGH PRESSURE STEAM  
LPS = LOW PRESSURE STEAM  
LPR = LOW PRESSURE RETURN (BOILER BLOWDOWN, LOW PRESSURE CONDENSATE-SEE DRAWING FOR SPECIFIC APPLICATION NOTES)  
V = VENT ( STEAM RELIEF, STEAM VENT, REFRIGERANT VENT-SEE DRAWING FOR SPECIFIC APPLICATION NOTES)  
CHR = CHILLED WATER RETURN  
CHS = CHILLED WATER SUPPLY  
HWR = HOT WATER RETURN  
HWS = HOT WATER SUPPLY  
PC = PUMPED CONDENSATE FROM BDHX AND STACK ECONOMIZER TO SURGE TANK AND DA

PCR = PUMPED CONDENSATE FROM SURGE TANK TO BDHX AND STACK ECONOMIZER  
BFW = BOILER FEEDWATER FROM STACK ECONOMIZER TO BOILER  
BFWR = BOILER FEEDWATER FROM DA TO STACK ECONOMIZER  
MW = MAKEUP WATER (NON POTABLE WATER-CAN BE SOFTENED OR CITY/EMERGENCY WATER)  
GRS = GLYCOL RADIATOR SUPPLY TO GENERATOR JACKET  
GRR = GLYCOL RADIATOR RETURN FROM GENERATOR JACKET  
GRS-AC = GLYCOL RADIATOR SUPPLY TO AFTERCOOLER  
GRR-AC = GLYCOL RADIATOR SUPPLY FROM AFTERCOOLER

DOCUMENT			
Document Date			
JSI-68	09/27/13		
JSI-50	02/21/13		
JSI-49	01/31/13		
JSI-48	01/22/13		
JSI-47	01/18/13		
JSI-46	12/22/12		
JSI-45	12/21/12		
JSI-44	12/19/12		
JSI-42	11/21/12		
JSI-038	10/26/12		

INITIAL	BW	JJ	N/A
DRAFTER	CPL	FIELD	

CONTRACT DOCUMENT LIST			
ENC			
ENLARGED BOILER ROOM PIPING PLAN - NORTHEAST			
CHR/CHS/HPS/HWR/HWS			

DYAMC			
ENC			
ENLARGED BOILER ROOM PIPING PLAN - NORTHEAST			
CHR/CHS/HPS/HWR/HWS			

rkmechanical			
3000 West Street, Danvers, CO 80020-3006			
T 303.355.9698 F 303.355.9698 W www.rkme.com			
FURNISH: J:\RK Projects\DYAMC\Sheets\ENC06.MH.401 ENLARGED BOILER ROOM PLAN.dwg			

FIELD SIGN-OFF DATE			
BY	DATE	BY	DATE
DHUYNH			
PROJECT NUMBER	06.MH.401		
2111-206			

Project Record  
Drawing  
6/13/2016  
Contractor: RK Mechanical, Inc.

