

**CONSOLIDATED QUESTIONS AND ANSWERS
SOLICITATION # 697DCK-23-R-00021
(Demo BGM OM, Binghamton NY)**

As of: 10/05/2022, 10:00 a.m.. EST

Page	Section	Para	Questions/Answers
BGM OM Final Specs, Page 19	01 35 43.13		Question 1. Typically, when we demo locations with lead paint, the painted surfaces are considered C&D and disposed of with the remainder of the C&D as long as they are not being repurposed. Broome county landfill accepts waste with lead paint in this manner. Given the small quantity of lead on this project, are we able to consider its contents as a portion of the whole project, thereby eliminating the need for lead abatement? This is a much more cost effective and commonly practiced procedure.
			Answer 1. Yes. The Lead Based Paint can be disposed of as C&D in lieu of abatement. A record of where the dumpsters are taken and documentation that the accepting landfill accepts such waste shall be provided in that instance as a deliverable to the FAA for our closeout documentation.

Notes:

Questions submitted/received by October 5, 2022, were considered timely and are included in this list. It is possible that some questions/answers may appear similar or duplicate but should not be in conflict while providing clarification/confirmation.