

1

2

3

4

GENERIC TELECOMMUNICATIONS MEDIA AND INTERFACE SPECIFICATIONS FOR TELECOMMUNICATION SPACES

ID	PRIMARY ATTRIBUTE	SECONDARY ATTRIBUTE	SPECIFICATION
1	COPPER PATCH PANELS	PERFORMANCE CATEGORY	CATEGORY 6A (10 GBE)
		POSITION COUNT	48
		FORM FACTOR	ANGLED
		SIZE	ONE RACK UNIT
		JACK COLOR CODING	A-SIDE BLUE / B-SIDE YELLOW
2	FIBER DISTRIBUTION PANELS	CASSETTE CAPACITY	12 CASSETTES OR 6 DOUBLE CASSETTES
		CASSETTE USER INTERFACES	LC DUPLEX CONNECTORS
		CASSETTE BACKBONE INTERFACES	MPO-12
		PERFORMANCE CHARACTERISTICS	OM4 LASER ENHANCED 40 GBE 50/125 MULTIMODE / OS1 9/125 SINGLE MODE
		FORM FACTOR	ONE (1) RU
3	UTP (HORIZONTAL AND FIRST LEVEL BACKBONE)	PERFORMANCE CATEGORY	CATEGORY 6A (10 GBE)
		PERFORMANCE SPECIFICATIONS	MEETS OR EXCEEDS TIA-EIA-568-C.2-10, T5B-155.
		JACKET COLOR	BLUE (HORIZONTAL), WHITE (1 ST LEVEL BACKBONE)
4	FIBER (HORIZONTAL AND FIRST LEVEL BACKBONE)	PERFORMANCE CATEGORY	OM4 LASER ENHANCED TO 40 GIGABIT ETHERNET (GBE) / OS1 / OS2
		PERFORMANCE SPECIFICATIONS	LASER OPTIMIZED 50/125 MM FIBERS WITH AT LEAST 4,700 MHZ-KM AT 850 NM / OS1 9/125 SM FIBERS (INTRA-BUILDING) / OS2 9/125 SM (INTER-BUILDING)
		MODE	MULTIMODE/SINGLE MODE (DISTRIBUTION TO TRs ONLY)
		JACKET COLOR	AQUA (OM4) / YELLOW (OS1/2)
		MEDIA CONNECTOR	PRE-TERMINATED WITH MPO, TYPE A
		STRAND COUNT	12 OR 24
		BUNDLING	LOOSE TUBE
5	UTP PATCH CORDS	PERFORMANCE CATEGORY	CATEGORY 6A, 26-GAUGE, STRANDED
		PERFORMANCE SPECIFICATIONS	CENTER TUNED TO HORIZONTAL MEDIA
		JACKET COLOR	BLUE
		TERMINATION METHOD	FACTORY PRE-TERMINATED
6	FIBER PATCH CORDS	PERFORMANCE CATEGORY	OM4 / OS1 / OS2
		PERFORMANCE SPECIFICATIONS	LASER OPTIMIZED 50/125 MM FIBERS WITH AT LEAST 4,700 MHZ-KM AT 850 NM / OS1 9/125 SM FIBERS (INTRA-BUILDING) / OS2 9/125 SM (INTER-BUILDING)
		MODE	MULTIMODE/SINGLE MODE (PATCH CORD TO TRs ONLY)
		JACKET COLOR	AQUA (OM4) / YELLOW (OS1/2)
		MEDIA CONNECTOR	PRE-TERMINATED WITH DUPLEX LC

1

2

3

4

Department of Veterans Affairs



IT Operations and Services
Solution Delivery



EDCT

ENTERPRISE DATA CENTER AND
INFRASTRUCTURE ENGINEERING

PROJECT:

CBOC INFORMATION
TRANSPORT SYSTEMS
SPECIFICATIONS

MARK	DATE	DESCRIPTION

ISSUE:

DRAWING No:

FILE: CBOC DESIGN TEMPLATE-v1.rvt

DESIGNED BY: KEVIN GRZELKA, CTDC

CHECKED BY: MICHAEL JULIAN, RCDD
KELLY BATES, DCIE

DOC VERSION No: 1.1

PRINT DATE: Jul 8, 2021

ISSUE DATE: Jul 8, 2021



SHEET TITLE

SPECIFICATIONS

SHEET: 3 OF 19

1 2 3 4

D
C
B
A



IT Operations and Services
Solution Delivery



EDCT
ENTERPRISE DATA CENTER AND
INFRASTRUCTURE ENGINEERING

PROJECT:
CBOC INFORMATION
TRANSPORT SYSTEMS
SPECIFICATIONS

MARK	DATE	DESCRIPTION

ISSUE:	
DRAWING No:	
FILE:	CBOC DESIGN TEMPLATE-v1.rvt
DESIGNED BY:	KEVIN GRZELKA, CTDC
CHECKED BY:	MICHAEL JULIAN, RCDD KELLY BATES, DCIE
DOC VERSION No:	1.1
PRINT DATE:	Jul 8, 2021
ISSUE DATE:	Jul 8, 2021

SHEET TITLE

TYPICAL BACKBOARD
RESERVATIONS

1 2 3 4


1 2 3 4

D

C

B

A



1 TYPICAL RACK ELEVATION FOR HEALTH CARE FACILITY TELECOMMUNICATIONS ROOMS

1 2 3 4

Department of Veterans Affairs



IT Operations and Services
Solution Delivery



EDCT

ENTERPRISE DATA CENTER AND
INFRASTRUCTURE ENGINEERING

PROJECT:
CBOC INFORMATION
TRANSPORT SYSTEMS
SPECIFICATIONS

MARK	DATE	DESCRIPTION

ISSUE:
DRAWING No:
FILE: CBOC DESIGN TEMPLATE-v1.rvt
DESIGNED BY: KEVIN GRZELKA, CTDC
CHECKED BY: MICHAEL JULIAN, RCDD
 KELLY BATES, DCIE
DOC VERSION No: 1.1
PRINT DATE: Jul 8, 2021
ISSUE DATE: Jul 8, 2021

SHEET TITLE
TYPICAL RACK ELEVATION



30 Amp 3-Phase PDU BASE UNIT – FRONT
(ZONIT ZON-C-ZPDU)
REQUIRES TWO 30 AMP 3-PHASE (WYE) CIRCUITS
WITH L21-30R RECEPTACLES
(OR EQUIVALENT)




PDU INPUTS REQUIRE
TWO L21-30Rs



30 Amp 3-Phase PDU BASE UNIT – REAR
FOUR (4) L21-20R
SIX (6) NEMA 5-15/20 T-SLOT
(OR EQUIVALENT)

NOTE: THE CORRECT SPECIFICATION FOR THE PDU IS TO FEED IT WITH A TWO POWER SOURCES. POWER INPUTS SHOULD ORIGINATE FROM TWO INDEPENDENT POWER SOURCES. EACH INPUT WILL USE IDENTICAL SPECS: WYE (5-WIRE) CONFIGURED, 208V, 30A, THREE-PHASE, TERMINATING IN A NEMA L21-30R LOCKING RECEPTACLE. THE NEUTRAL CONDUCTOR SHOULD BE UPSIZED ONE GAUGE TO MATCH THE UPSIZED NEUTRAL CONDUCTORS IN THE PDU UNITS. THE NEUTRAL "UPSIZING" SHOULD IDEALLY BE CONTINUED IN THE POWER DISTRIBUTION SYSTEM BACK TO THE UPS OR TRANSFORMER WINDING POLE. THIS INCREASES THE EFFICIENCY OF THE POWER DISTRIBUTION SYSTEM AND SUPPRESSES HARMONICS IN THE SYSTEM.

⑤ TYPICAL ZONE PDU UNIT WITH REAR DETAIL AND ADAPTORS REQUIRED FOR VERTICAL PDU



DUAL 3-PHASE 480 VOLT INPUTS

(WITH 480 – 208
TRANSFORMER)

BUS OR FEEDER

ZONE PDU

RACK MOUNT UPS

"ZERO U" VERTICAL PDU

DUAL POWER SUPPLY


② NOTIONAL POWER SCHEMATIC FOR INFORMATION ONLY – NOT FOR CONSTRUCTION



APC AP7900 RACK PDU, SWITCHED, 1U, 15A, 100/120V, (8) 5-15 APC
SWITCHED RACK PDU, INPUT: 120V (OR EQUIVALENT)

④ 110 Volt PDU FOR PLACEMENT AS NEEDED

NOTE: THIS DESIGN PROVIDES DIVERSE POWER INPUTS FOR ACTIVE EQUIPMENT BY SPLITTING THE SOURCE POWER ACROSS TWO INPUTS ON THE ZONE PDU. EACH INPUT WILL SUPPORT TWO EQUIPMENT-FACING PDUs. EACH SERVER CABINET WILL CONTAIN A MINIMUM OF TWO EQUIPMENT-FACING PDUs – EACH WILL BE ENERGIZED BY SEPARATE ZONE PDU INPUTS.



ONE ZONE PDU FOR TWO
SERVER CABINETS/
NETWORK RACKS

① POWER SCHEMATIC FOR POWER RACK- LEVEL REDUNDANCY



APC AP8861 RPDUs OR EQUIVALENT; RACK PDU 2G, METERED; L21-20 PLUG;
THREE PHASE; 120/208V INPUT; 20A; ZERO U,
5.7 KW, 208V, (36) C13 & (6) C19 & (2) 5-20 OUTLETS; FOR USE IN
TELECOMMUNICATION ROOMS AND LOCATIONS WITH LEGACY 110V ONLY
EQUIPMENT



REQUIRES ONE (1) L21-
20R

③ 208 VOLT PDU FOR EQUIPMENT POWER – TO BE ENERGIZED BY ZONE PDU

Department of Veterans Affairs

IT Operations and Services
Solution Delivery

EDCT
ENTERPRISE DATA CENTER AND
INFRASTRUCTURE ENGINEERING

PROJECT:

CBOC INFORMATION
TRANSPORT SYSTEMS
SPECIFICATIONS

MARK	DATE	DESCRIPTION

ISSUE:

DRAWING No:
FILE: CBOC DESIGN TEMPLATE-v1.rvt
DESIGNED BY: KEVIN GRZELKA, CTDC
CHECKED BY: MICHAEL JULIAN, RCDD
KELLY BATES, DCIE
DOC VERSION No: 1.1
PRINT DATE: Jul 8, 2021
ISSUE DATE: Jul 8, 2021

SHEET TITLE

TYPICAL RACK POWER
DISTRIBUTION

L21-30P SIDE A
REQUIRES A 208V, 30A, THREE-PHASE CIRCUIT,
TERMINATING IN A NEMA L21-30R LOCKING RECEPTACLE.


L21-30P SIDE B
REQUIRES A 208V, 30A, THREE-PHASE CIRCUIT, TERMINATING
IN A NEMA L21-30R LOCKING RECEPTACLE.

ZONE PDU
30A 3-PHASE ZONE PDU BASE UNIT - REQUIRES
TWO 30A 3-PHASE (WYE) CIRCUITS WITH L21-30R
RECEPTACLES

ZONE PDU
30A 3-PHASE ZONE PDU BASE UNIT - REQUIRES
TWO 30A 3-PHASE (WYE) CIRCUITS WITH L21-30R
RECEPTACLES

RACK-MOUNTED 5 KW, 208V UNINTERRUPTIBLE POWER
SUPPLY (UPS) WITH NEMA 20A L21-20P INPUT AND L21-
20R OUTPUT

① POWER SCHEMATIC RACKS - REAR VIEW



IT Operations and Services
Solution Delivery



EDCT

ENTERPRISE DATA CENTER AND
INFRASTRUCTURE ENGINEERING

PROJECT:

CBOC INFORMATION
TRANSPORT SYSTEMS
SPECIFICATIONS

MARK	DATE	DESCRIPTION

ISSUE:

DRAWING No:

FILE: CBOC DESIGN TEMPLATE-v1.rvt

DESIGNED BY: KEVIN GRZELKA, CTDC

CHECKED BY: MICHAEL JULIAN, RCDD
KELLY BATES, DCIE

DOC VERSION No: 1.1

PRINT DATE: Jul 8, 2021

ISSUE DATE: Jul 8, 2021

SHEET TITLE

POWER DISTRIBUTION

- RACK = RK1 THROUGH RK4. LABELED LEFT TO RIGHT WHEN LOOKING AT THE FRONT OF THE RACK. APPLIES TO RACKS AND CABINETS.
- UTP PATCH PANEL = CPL-RACK NAME-01 THROUGH 45. EXAMPLE: CPL-RK1-01 FOR THE PANEL LOCATED IN RACK UNIT #1 IN RACK #1.
- UTP PATCH PANEL POSITION = PANEL ID.01 THROUGH 24. EXAMPLE CPL-RK1-01.01
- FIBER DISTRIBUTION PANEL = FDP-RACK NAME-01 THROUGH 45. EXAMPLE: FDP-RK1-01 FOR THE PANEL IN RACK UNIT #1 RACK #1.
- FIBER DISTRIBUTION CASSETTE = FDC-RACK NAME-01 THROUGH 45.1 THROUGH 3. EXAMPLE: FDC-RK1-01.1 FOR THE CASSETTE IN POSITION #1 IN PANEL LOCATED IN RACK UNIT #1 IN RACK #1.
- UTP PATCH CORDS = CCA[SOURCE.PORT]/[DESTINATION.PORT]. EXAMPLE CCA[CPL-RK1-01.01]/[CPL-RK2-02.02] AS A PATCH CORD CONNECTING PORT #1 IN THE COPPER PATCH PANEL LOCATED IN RACK #1, RACK UNIT #1 WITH PORT 2 LOCATED IN RACK 2, RACK UNIT #2.
- FIBER PATCH CORDS = FCA[SOURCE.PORT]/[DESTINATION.PORT]. EXAMPLE FCA[FDP-RK1-01.01.01]/[FDP-RK2-02.02.02] AS A PATCH CORD CONNECTING PORT #1 IN THE FIBER PATCH PANEL LOCATED IN RACK #1, RACK UNIT #1 WITH PORT 2 LOCATED IN RACK 2, RACK UNIT #2.
- FACEPLATE = TR ROOM NUMBER-PATCH PANEL ID.PORT. EXAMPLE. 1A-CPL-RK1-01.1 FOR TELECOMMUNICATIONS ROOM 1, UTP PANEL IN RACK #1, RACK UNIT #1, PORT POSITION #1.

① EXAMPLE INSIDE PLANT ADMINISTRATION

Department of Veterans Affairs



IT Operations and Services
Solution Delivery



EDCT

ENTERPRISE DATA CENTER AND
INFRASTRUCTURE ENGINEERING

PROJECT:

CBOC INFORMATION
TRANSPORT SYSTEMS
SPECIFICATIONS

MARK	DATE	DESCRIPTION
------	------	-------------

ISSUE:

DRAWING No:

FILE: CBOC DESIGN TEMPLATE-v1.rvt

DESIGNED BY: KEVIN GRZELKA, CTDC

CHECKED BY: MICHAEL JULIAN, RCDD
KELLY BATES, DCIE

DOC VERSION No: 1.1

PRINT DATE: Jul 8, 2021

ISSUE DATE: Jul 8, 2021

SHEET TITLE

CBOC ITS NAMING STANDARDS


1 2 3 4

D

C

B

A



1 TYPICAL TOP-DOWN VIEW
NTS

1 2 3 4

Department of Veterans Affairs

IT Operations and Services
Solution Delivery

EDCT

ENTERPRISE DATA CENTER AND
INFRASTRUCTURE ENGINEERING

PROJECT:
CBOC INFORMATION
TRANSPORT SYSTEMS
SPECIFICATIONS

MARK	DATE	DESCRIPTION

ISSUE:

DRAWING No:

FILE: CBOC DESIGN TEMPLATE-v1.rvt

DESIGNED BY: KEVIN GRZELKA, CTDC

CHECKED BY: MICHAEL JULIAN, RCDD
KELLY BATES, DCIE

DOC VERSION No: 1.1

PRINT DATE: Jul 8, 2021

ISSUE DATE: Jul 8, 2021

SHEET TITLE

TELECOMMUNICATIONS
ENCLOSURE (TOP VIEW)

SHEET: 16 OF 19

1

2

3


4

D

C

B

A



1 ELEVATION FOR TELECOMMUNICATIONS ENCLOSURE

1

2

3

4



PROJECT:
CBOC INFORMATION
TRANSPORT SYSTEMS
SPECIFICATIONS

MARK	DATE	DESCRIPTION

ISSUE:

DRAWING No:

FILE: CBOC DESIGN TEMPLATE-v1.rvt

DESIGNED BY: KEVIN GRZELKA, CTDC

CHECKED BY: MICHAEL JULIAN, RCDD
KELLY BATES, DCIE

DOC VERSION No: 1.1

PRINT DATE: Jul 8, 2021

ISSUE DATE: Jul 8, 2021

SHEET TITLE

TELECOMMUNICATIONS
ENCLOSURE (ELEVATION VIEW)

