

QUESTIONS	ANSWERS
Would wood butcher block tops be acceptable alternate?	Butcher Block is not an acceptable material due to its tendency to warp over time.
Is there any material or stain color that is requested?	There is no material or stain color that is requested for the tabletop. The SOW outlines the minimum characteristics for the tabletop and quotes will be analyzed in conjunction with those characteristics.
Would the tie down and bar for spool be provided by us?	The government expects vendors to provide the tie down bracket (described in the SOW) and .5" (diameter) bar for the spool.
Do you have a timeline you need these installed by?	Leadtime must be included in your quote as it is a determining factor under 52.212-2.
Do you have photos of existing tables?	No photos of the existing tables will be provided. Please follow the minimum characteristics written in the Statement of Work under Part (5) and Attachment 1 in the solicitation.