

2. AMENDMENT/MODIFICATION NUMBER 0006	3. EFFECTIVE DATE 3/6/2023	4. REQUISITION/PURCHASE REQ. NUMBER 603-23-3-2311-0003	5. PROJECT NUMBER (if applicable) 603-22-601
--	-------------------------------	---	---

6. ISSUED BY Department of Veterans Affairs Network Contracting Office 9 (90C) NCO 9 1639 Medical Center Parkway, Suite 400 Murfreesboro TN 37129	CODE 90C	7. ADMINISTERED BY (If other than Item 6) Network Contracting Office 9 Department of Veterans Affairs Network Contracting Office (90C) 1639 Medical Center Parkway Suite 400 Murfreesboro TN 37129	CODE 90C
--	-------------	---	-------------

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders	(X)	9A. AMENDMENT OF SOLICITATION NUMBER 36C24923R0031
	<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 03-06-2023
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NUMBER
		10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
The purpose of this amendment is to respond to additional RFI's.
See attached.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Jeffery A. Ridenour Contracting Officer
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)
15C. DATE SIGNED	16C. DATE SIGNED

CONTINUATION PAGE

**Project Name: Louisville ASU PACU Safety Improvements
Project No.: 603-22-601**

RFI #	QUESTION	RESPONSE	TO BE ANSWERED BY	Discipline
111	VALIANT realizes that the RFI submission date has passed, however, schedule concerns exist resulting from conversations with the specified Nurse call vendor. VALIANT is being told that the delivery of the Nurse call systems can be up to 5-6 months from the order. The fabrication of the Nurse call exceeds the solicitation period of performance. Since the Nurse call system is an ILSM issue VALIANT wanted to alert the owner, and request clarification as to the contractual period of performance.	If the contractor knows there are long lead times on materials that will impact the contract period of performance, the contractor needs to provide that information in their proposal and request an extension to the period of performance.	VA	
112	Response to RFI# 01 – Are the Self-Perform calculations to be place in the Technical Proposal?	Self-Perform calculations are to be submitted as a separate document.	VA	
113	Response to RFI# 63 states that an alternative Nurse Call System other than Rauland cannot be used. Several other RFIs state the contractor can use an alternate. Is the contractor allowed to use other than Rauland?	Yes. The VA will accept a Hillrom nurse call system that ties into the existing Hillrom nurse call system.	VA	
114	Response to RFIs 39, 40, 43, 45, 56, 93, 95, and 106 state that the Nurse call is a Stand-Alone System and the Head In equipment is located in Room C-411. RFI 110 state the VA will accept a Hillrom System and to delete work in Room C-411. This would be the Head-In Equipment. Is the VA stating that Rauland would be a stand-alone system, but Hillrom can be tied into the existing Hillrom System?	The Rauland system is a stand-alone system requiring the Head-In equipment located in Room C-411. The Hillrom system is tied into the existing Hillrom nurse call system in room A-454. Room A-454 holds the existing Hillrom nurse call Head-In equipment. Room A-454 is where the Hillrom system will tie-in. With a Hillrom system there is no need for Head-In equipment in room C-411 therefore no need for the additional room in C-411 related to the nurse call Head-in equipment. The restroom renovation of Room C-411 shown on the drawings remains except for the area related to the nurse call Head-in equipment. The area shown in room C-411 related to the nurse call Head-in equipment is deleted from the work.	VA	