

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE		PAGE OF PAGES 1 1	
2. AMENDMENT/MODIFICATION NO. 0001		3. EFFECTIVE DATE 09/05/2023		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY USDA-FS CSA NORTHWEST 4 1220 SW 3RD AVE STE 310 PORTLAND OR 97204-2829		CODE 40BF		7. ADMINISTERED BY (If other than Item 6)		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(x) 9A. AMENDMENT OF SOLICITATION NO. 1240BF23Q0070			
				x 9B. DATED (SEE ITEM 11) 08/25/2023			
				10A. MODIFICATION OF CONTRACT/ORDER NO.			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended , by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted ; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted , such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
<b>13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>							
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
	D. OTHER (Specify type of modification and authority)						
<b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) See QA1 attached.							

Except as provided herein, all terms and conditions of the document referenced in Item 9 A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)		_____ (Signature of Contracting Officer)	

Previous edition unusable
STANDARD FORM 30 (REV. 11/2016)  
Prescribed by GSA FAR (48 CFR) 53.243

**Q1:** What is the anticipated award date?

**A1:** As soon as possible after quotes due date and before 9.30.23.

. . . . .

**Q2:** What is the anticipated delivery date of the structure when awarded?

**A2:** Without knowing production timelines it would be nice to have the structure before snowfall this winter or in the spring of 2024 with delivery no later than April 1, 2024.

. . . . .

**Q3:** Base Building Item E Exterior Dimensions: Side walls shall be a minimum of 8 ft from prepared surface to curve of arch. Our standard 40' structures have a straight wall of 4' before the curve of the arch (see attached beam section clearances). At 2' from the interior wall the clearance would be 10'5". Will this meet your project requirements, or do you require the full 8' of straight wall?

**A3:** This is acceptable. The clearances in the provided sketch are acceptable for the purposes of the structure.

. . . . .

**Q4:** Optional Building Items #2 Insulation: Provide insulation package for all building surfaces at an R value of R-30. The standard insulation package for our 40' structures is R-25. Will this be accepted?

**A4:** R-25 would be acceptable.