

Project No.: OR DOT 18(2), OR58: Fix it Corridor Culverts
Project

Check General or Technical

#	General	Technical	Question	Answer	Date
1		x	I am bidding on the guardrail portion of this project. Bid Item A1000 is for Buried in Backslope Terminal by the each, but they have a minimum of 125 Lnft per the standard drawing. Sheet # D.13 has a length of 85 Lnft and sheet # D.14 has a length of 77 Lnft. Please advise.	The limits/lengths listed on sheets D.13 and D.14 are those of existing guardrail installations. New guardrail needs to meet minimum lengths per the standard drawings	11/15/22
2		X	Is there a Pre Bid Conference for the OR58: Fix-It Corridor Culverts Project?	At this time, we are not planning on having a pre-bid conference. If you have any questions about the Invitation for Bid (IFB), plans, or specs, please email wfl.plans-spec@dot.gov, and we will publicly post responses to your questions on SAM.gov.	11/16/22