

**Questions and Answers during Advertisement for  
NM FLAP SIE 10(1), Lakeshore Road**

**May 10, 2023**

<b>Questions</b>		<b>Answers</b>
<b>1</b>	153.02 (a)(1) (b) will a technician with New Mexico TTCP certification qualify as equivalent to (NICET) Level III?	New Mexico TTCP certification will not be accepted in lieu of NICET Level III.
<b>2</b>	153.05 (b) Testing. Can the Contractor utilize an established Commercial Laboratory within 90 miles of the Project in lieu of furnishing an equipped laboratory on-site as described in section 154.04B?	A commercial laboratory is allowed as long as meets the reporting time and other requirements listed in the SCR and FP14.