

Wetland Permit Work Questions and Answers 5/15/2023

1. Will FNAL be providing additional coordinates for work limit boundaries, stockpile areas and lined channels?

A: Yes, revised drawing will be provided prior to Notice to Proceed.

2. Can straw waddles be used in lieu of a silt fence?

A: No. Straw waddles will not be adequate to protect the adjacent wetlands.

3. How long is project site radiological training for this job?

A: Approximately 1 hour, this includes Subcontractor Orientation as well as General Employee Radiation Training (GERT).

4. Are we to provide professional photographic documentation? Before ,during, and after?

A: No, a professional photographer is not required (photos may be taken by subcontractor staff). Photography should be performed in accordance with Section 01 32 33.