

Salient Characteristics

The contractor shall provide and deliver 2200 feet of High Voltage Cable possessive of the salient characteristics below.

- 2 Spools of 1100ft of High Voltage Cable (Okonite Brand or Equal)
- Spools no greater than 4ft. in Diameter
- 250 MCM
- Class B Copper
- EPR insulation. Insulation level of 133% EPR insulation required.
- 14 X #12 Copper Concentric Wires (Third Neutral) *concentric copper cable is required. Copper tape shielding instead of concentric copper is not acceptable.
- Seq Print - 15KV