



DRAWING KEYNOTES

- 1 305x255 ABOVE TO ERV-2. 305x205 BELOW TO ERV-3.
 - 2 305ø ABOVE AND BELOW.
 - 3 WC-2 ABOVE AND WC-3 BELOW.
 - 4 PROVIDE FIRE DAMPER AT FLOOR.
- 9 M6 M8

DRAWING NOTE

1. THE CONTRACTOR SHALL NOT USE POWDER DRIVEN FASTENERS FOR SUPPORT OF MECHANICAL COMPONENTS WHEN LOADED IN TENSION.



PROJECT RECORD DRAWINGS

REPLACE FIRE STATION

05/30/2007

ARCHITECT:
OAK POINT ASSOCIATES
CONTRACTOR:
RICCI CONSTRUCTION CO., INC.

Rev.	Description	By	Date
1	REFER TO CLARIFICATION SKETCHES	RJC	08/10/07
2	AS-BUILT REVISIONS	RJC	08/10/07

REPLACE ANG FIRE STATION
PROJECT NO. SZCQ009014

15th CIVIL ENGINEER SQUADRON
MECHANICAL PLANS

NEW HAMPSHIRE

NEWINGTON

PROJECT RECORD DRAWINGS

Project No.	20002.01
Proj. Manager	KTW
Proj. Designer	SMC
Drawn By	SMC
Checked By	RPG
Scale	AS NOTED
Approved	
Date	07/15/04

M6

Sheet 54 of 83

