

## ADDENDUM

October 6, 2022

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the above noted project, fully and completely as if the same were fully contained therein.

### Drawings:

#### 1. Sheet A601:

Cardio OR-1, Robotics OR-2, Neuro OR-3, General OR-4 and ENT OR-5 are to receive Stonhard Stonres STR as follows:

RES-3C is Stonhard Stonres STR Fossil to be installed in the operating room sterile zone (center area).

RES-3D is Standard Stonres STR Bluestorm to be installed in the operating rooms surrounding the sterile zone.

### Basis of Design

Stonhard Stonres STR is a resilient urethane flooring system.

Stonhard Stonblend GSI-G is an epoxy flooring system.

Follow manufacturer's installation instructions and requirements. Manufacturer's requirements for Stonhard products or approved equal will supersede conflicts with specification Section 09 67 23.30 (RES-3) Resinous (Epoxy Base) High Performance Flooring.

End of Addendum